

WASTE HAULER  
UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

LET 06  
9/11/79

SUBJECT: Vaydik Inc.

NEW

DATE: Sept 11, 1979

FROM: A. Rutter

TO: File

On Sept 10, 1979 I received notification from Lt Miller of the Maywood Fire Dept of a hazardous situation at Vaydik Inc an industrial waste hauler licensed by the state of Illinois, EPA# 0059/003. I visited the facility on Sept 11, 1979 and I found 38 - 55gal open drums of paint waste, 55gal drums of various solvents including methylketone, Methylal and acetone. Also found were 4 - 6000g tanks one of which contained waste oil and an old truck used for waste oil storage - none of which were diked.



over

The company was written up  
for an EPC violation. The Maywood  
Fire Dept became involved when some  
of the solvents were spilled. Evidence  
suggested small spills of waste oil  
& other liquids had occurred.

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
SPILL PREVENTION CONTROL AND COUNTERMEASURE  
PLAN VERIFICATION ☐ or NOTICE OF VIOLATION ☒

File No. \_\_\_\_\_

A. INFORMATION RELATED TO OWNER/OPERATOR:

1. Name Vaydik Inc.
2. Address 2010 W MADISON ST MAYWOOD IL 60153
3. Company Official Bill Vaydik <sup>Office</sup> Telephone 312 681 3999
4. Type business organization WASTE HAULER
5. Registered Agent (if Known) \_\_\_\_\_

B. INFORMATION RELATED TO FACILITY:

1. Name SAWE
2. Address \_\_\_\_\_
3. Person in Charge \_\_\_\_\_ Telephone \_\_\_\_\_
4. Facility manned 8 hrs/day: Yes ☒ No ☐
5. Facility Oil storage areas have secondary containment: Yes ☐ No ☒
6. Brief description of facility: WASTE

Company claims oil spill from this facility could not reasonably be expected to reach surface waters because of: N/A

C. INFORMATION RELATED TO SPOC PLAN:

1. What kind of oil (s) stored at facility? WASTE OIL, PAINT  
WASTE
2. What is total storage capacity of facility?
  - a. Above ground storage 24,000 gallons. <sup>+ 38-55 gal open drums of paint was</sup>
  - b. Buried, underground storage \_\_\_\_\_ gallons.
3. Would spill be expected to reach water course? Yes ☒ No ☐  
Distance from tankage to nearest flowing water 200 ft meters.
4. Name of nearest surface waters: City Sewer
5. SPOC Plan available during regular working hours? Yes ☐ No ☒  
But plan at nearest Field Office? Yes ☐ No ☒  
State spill plan only: ☐  
Claims plan developed, but location unknown ☐

6. Who did you ask Plan?

Name:

Title:

Date:

Bill Lyrik

OWNER

9:20 AM

Time 9-11-79

7. Plan certified by Licensed Engineer?

Yes ☐

No ☐

N/A

Name:

State Registration No. \_\_\_\_\_

8. Owner reviewed plan on

N/A

Has not reviewed plan by 1/10/78. ☐

9. Facility has certified contingency type plan with a commitment of manpower & equipment on site? Yes ☐ No ☒ Explain \_\_\_\_\_

10. Extension on file: Yes ☐

No ☒

Unknown ☐

Date: \_\_\_\_\_

11. Plan properly implemented: Yes ☐

No ☐

N/A

If No, list nonimplemented items: \_\_\_\_\_

D. OIL SPILL HISTORY:

1. Prior spill over 1,000 gallons within year: Yes ☐

No ☒

2. Two (2) minor spills within year: Yes ☐

No ☒

Case No.'s. (if appropriate): \_\_\_\_\_

3. Extensive spill history (attach list): Yes ☐

No ☒

4. SPCC Plan verification as result of spill: Yes ☐

No ☒

Case No.: \_\_\_\_\_

E. RESPONSIBLE OFFICIAL NOTIFIED OF 40 CFR 112.4 requirements: Yes ☒

No ☐

RESPONSIBLE OFFICIAL NOTIFIED OF 40 CFR 112.5 requirements: Yes ☒

No ☐

Name:

Bill Vaydik

Title:

OWNER

Date:

9-11-79

SUMMARY OF SPCC PLAN VIOLATION (s):



Not developed.

Not certified.

Not implemented.

Not available.

Not reviewed.

Anthony Rutter 9-11-79  
(Investigator) Date  
DISTRICT OFFICE Central